



9D02-07.30 BLR FW VLV DMD

BLR DRUM LEVEL 9D02-07.30

AI 1	{	PWR	TB1-1	DRUM LEVEL
	+		TB1-2	
	-		TB1-3	
AI 2	{	PWR	TB1-4	
	+		TB1-5	
	-		TB1-6	
AI 3 (OPTIONAL TEMP)	{	PWR	TB1-7	
	+		TB1-8	
	-		TB1-9	
AI 4 (OPTIONAL TEMP)	{	PWR	TB1-10	
	+		TB1-11	
	-		TB1-12	
AD 1	{		TB1-13	FEEDWATER VALVE
	-		TB1-14	
AD 2	{		TB1-15	
	-		TB1-16	
DI 1	{	PWR	TB2-12	DRUM LEVEL
	+		TB2-11	
	-		TB2-10	
DI 2	{	PWR	TB1-1	FEEDWATER VALVE
	+		TB1-1	
	-		TB1-1	
DI 3 (OPTIONAL PULSE)	{	PWR	TB1-1	DRUM LEVEL
	+		TB1-1	
	-		TB1-1	
DO 1	{		TB2-20	FEEDWATER VALVE
	-		TB2-19	
DO 2	{		TB2-18	FEEDWATER VALVE
	-		TB2-17	
DO 3	{		TB2-16	FEEDWATER VALVE
	-		TB2-15	
DO 4	{		TB2-14	FEEDWATER VALVE
	-		TB2-13	
DC PDIVER		+24 VDC	TB2-3	FEEDWATER VALVE
		CDM	TB2-2	
		CDM	TB2-1	
MODULE BUS		MOD BUS	TB1-17	
		CDM	TB1-18	
BUS		MOD BUS	TB1-19	
		CDM	TB1-20	
AC PDIVER		L1/H	TB3-1	
		GND	TB3-2	
		L2/N	TB3-3	
RTD INPUTS		SHLD/GND	TB3-4	
		CJC+	TB4-1	
		CJC-	TB4-2	
		RTD COM1	TB4-3	
		RTD COM2	TB4-4	

DI 3	J1	N/A	AI 3	J5	N/A	AI 4	J6	N/A
DI 3	J2	N/A	AI 3	J4	N/A	AI 4	J3	N/A

J1/J2 2-3 STANDARD, 1-2 PULSE
 J3-J6 2-3, 4-5 STANDARD, 1-2,2-3 TEMPERATURE (NON-STANDARD REQUIRE OPTION BOARD)
 POWER SUPPLY BOARD JUMPERS:

V101	V106	V110
1	1	E3

W101 - 0 FOR 220/240 VAC, 1 FOR 120 VAC
 W106 - 0 FOR ISOLATED DC/AC GROUNDS
 W110 - E3 FOR VAC ONLY, E4 FOR DC OR BOTH AC AND DC

TERMINATION BOARD SWITCHES:

	AI 1	AI 2	AI 3	AI 4	AD 1	AD 2	DI 1	DI 2	DI 3
S1	10	9	8	7	6	5	3	2	1
	1	1	1	1	0	0	0	0	0

AI'S 0 = VOLTAGE, 1 = CURRENT
 AD'S 0 = CURRENT, 1 = VOLTAGE
 DI'S 0 = ISOLATED, 1 = NON-ISOLATED

1 = CLOSED/ON (JUMPER INTACT)
 0 = OPEN/OFF (JUMPER CUT)

INTEGRAL CONTROL SYSTEM SERVICES, INC.
 1303 SACKETT AVENUE
 Cuyahoga Falls, Ohio 44223
 Office: 330-923-8900 Fax: 330-923-2118

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. NEITHER THE DRAWING, NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS. NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE INJURIOUS TO INTEGRAL CONTROL SYSTEM SERVICES, INC.

AutoCAD NAME: 0000801A.dwg

LA	12/00	DRAWING NO.	PART NO.
APPROVED BY	DATE	THIS SHEET ALSO USED FOR	
DIMENSIONAL TOLERANCES UNLESS OTHERWISE SPECIFIED:			
MILLIMETRES		INCHES	
1 PLACE = 0.3 mm	2 PLACE = .01		
2 PLACE = 0.003 mm	3 PLACE = .001		
3 PLACE = 0.015 mm	4 PLACE = .0005		
MARK IDENTIFICATION AND MATERIAL NUMBERS ON TOOL DETAILS. MARK IDENTIFICATION NUMBERS ON STRUCTURAL WORK.			
3rd ANGLE PROJECTION			

QTY.	LINE NUMBER(S)	MANUFACTURER/DESCRIPTION	PART (MODEL) #
	PART NO.	SHEET 1	SHEETS 2
		DRAWING NO. 6000001	
DESIGN BY	DET. BY	TITLE	
LA	MM	Boiler Drum Level	
DESIGNED BY	SAFETY BY	SLC_1 EXTERNAL CONNECTION DRAWING	
DATE	SCALE	DIVISION:	
	N/A	PLANT:	
		LOCATION/ACTIVITY:	

LOOP 1
 PCU 1
 MADR 8