


| ITEM | QTY. | DESCRIPTION |
|------|------|---|
| 1 | 4 | 1/2" PLUG SOLID F.C. STL. THRD. |
| 2 | 2 | 1/2" TEE 3000#, 304 S.S. THRD. |
| 3 | 2 | 1/2" X 4" LG. PIPE NIPPLE SCH. 80S 304 S.S. SEAMLESS, THRD. |
| 5 | 2 | 1/2" GLOBE VA. 316 STAINLESS STL. HEX NO. HN-491-1U3331411 OR EQUAL. |
| 6 | 6 | 3/8" O.D. X 1/2" MALE CONN. 316 S.S. SWAGELOCK |
| 7 | 1 | 3-VALVE MANIFOLD FURN. WITH TRANS. |
| 8 | * | 3/8" O.D. X .035" WALL TUBING 316 S.S. |
| 9 | 2 | 3/8" O.D. TUBE TEE 316 S.S. SWAGELOCK |
| 10 | 1 | FLOOR MOUNT O'BRIEN #F-52 OR EQUAL |

* DETERMINE IN FIELD




LEGEND
L-LOW
H-HIGH

AutoCAD NAME: FLOWTRANS1.dwg

INTEGRAL CONTROL SYSTEM SERVICES, INC.

1303 SACKETT AVENUE
 Cuyahoga Falls, Ohio 44223
 Office: 330-923-6900 Fax: 330-923-2116

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. NEITHER THE DRAWING NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS. NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE INJURIOUS TO INTEGRAL CONTROL SYSTEM SERVICES, INC.

| | | | |
|--|------|---|----------|
| APPROVED BY | DATE | DRAWING NO. | PART NO. |
| THIS SHEET ALSO USED FOR | | | |
| <small>DIMENSIONAL TOLERANCES UNLESS OTHERWISE SPECIFIED: MILLIMETERS INCHES 1 PLACE ± 0.3 mm 2 PLACE ± .01 3 PLACE ± 0.013 mm 3 PLACE ± .001 4 PLACE ± 0.008 mm 4 PLACE ± .0005</small> | |  <small>3rd ANGLE PROJECTION DO NOT SCALE DRAWING</small> | |

| | | | |
|---------|----------------|--|----------------|
| QTY. | LINE NUMBER(S) | MANUFACTURER/DESCRIPTION | PART (MODEL) # |
| | | | 042601-1 |
| DES. BY | DET. BY | TITLE | |
| LA | MM | INSTRUMENT PIPING DETAIL FLOW TRANSMITTER | |
| DATE | SCALE | DIVISION: | |
| | NONE | PLANT: | |
| | | LOCATION/ACTIVITY: | |