



INST TAG NUMBER	ITEM	ELEVATION	MOUNTING	SERVICE
BI-369	FLAME SCANNER	25'-2"	FIELD	BURNER #1 FLAME EAST
BI-370	FLAME SCANNER	25'-2"	FIELD	BURNER #1 FLAME WEST
BI-371	FLAME SCANNER	25'-2"	FIELD	BURNER #2 FLAME EAST
CD-333	CONTROL DRIVE	20'-2"	FLOOR	BLAST FURNACE GAS VALVE
CD-336	CONTROL DRIVE	20'-2"	FLOOR	HOT AIR DAMPER
CV-341	CONTROL VALVE	25'-2"	IN-LINE	FEEDWATER CONTROL VALVE
PT-325	DRAFT RANGE TRANSMITTER	25'-2"	PM 2	AIR TO BURNER
PT-328	PRESSURE TRANSMITTER	25'-2"	PM 2	BFG PRESSURE EAST
PT-329	PRESSURE TRANSMITTER	25'-2"	PM 2	BFG PRESSURE WEST
TVI-343	TV CAMERA	25'-2"	WM 1	BOILER FRONT CAMERA
ZS-350	LIMIT SWITCH	25'-2"	FIELD	BFG VALVE OPEN/CLOSED
ZS-353	LIMIT SWITCH	25'-2"	FIELD	BFG VALVE OPEN/CLOSED
ZS-358	LIMIT SWITCH	25'-2"	DN VALVE	HOT AIR DAMPER OPEN/CLOSED
BI-372	FLAME SCANNER	25'-2"	FIELD	BURNER #2 FLAME WEST

BOILER #3
 OPERATOR FLOOR EL. 20'-2"
 LEVEL 2

NOTES:

- ① WM- WALL MOUNTED
- ② PM- PIPE STAND MOUNTED
- ③ RM- RACK MOUNTED

AutoCAD NAME: .dwg

INTEGRAL CONTROL SYSTEM SERVICES, INC.
ICSS 1303 SACKETT AVENUE
 Cuyahoga Falls, Ohio 44223
 Office: 330-923-6900 Fax: 330-923-2118

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. NEITHER THE DRAWING, NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS. NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE INJURIOUS TO INTEGRAL CONTROL SYSTEM SERVICES, INC.

APPROVED BY: _____ DATE: _____

DRAWING NO. _____ PART NO. _____

THIS SHEET ALSO USED FOR _____

DIMENSIONAL TOLERANCES UNLESS OTHERWISE SPECIFIED:
 MILLIMETRES INCHES
 1 PLACE ± 0.3 mm 2 PLACE ± .01
 2 PLACE ± 0.003 mm 3 PLACE ± .001
 3 PLACE ± 0.015 mm 4 PLACE ± .0005

3rd ANGLE PROJECTION
 DO NOT SCALE DRAWING

QTY		LINE NUMBER(S)	MANUFACTURER/DESCRIPTION	PART (MODEL) #
				000001-0
DES.BY	DET.BY	TITLE		
LA	MM	I&C INSTALLATION STEEL MILL # 3		
CHECKED BY	SAFETY OK			
DATE	SCALE	DIVISION:		
		PLANT:		
		LOCATION/ACTIVITY:		