



LEGEND:
 ▽ VERTICAL FIELD TERMINATION SHIELD BUS

- NOTES:**
1. ALL UNTERMINATED SHIELDS TO BE PULLED BACK AND TAPED.
 2. ALL CABLE IS #18 SHIELDED TWISTED PAIR UNLESS INDICATED OTHERWISE.

- REFERENCE DRAWINGS:**
- POLYMERIZATION PROCESS PCU 2 EXTERNAL
 - POLYMERIZATION PROCESS PCU 2 EXTERNAL
 - P&ID C-800 BATCH TANKS SHEET 1 OF 2
 - P&ID C-800 BATCH TANKS SHEET 2 OF 2
 - P&ID POLYMERIZATION SHEET 1 OF 4

AutoCAD NAME: Tfb-tai6.dwg

INTEGRAL CONTROL SYSTEM SERVICES, INC.
 1303 SACKETT AVENUE
 Cuyahoga Falls, Ohio 44223
 Office: 330-923-6900 Fax: 330-923-2118

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. NEITHER THE DRAWING, NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS. NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE INJURIOUS TO INTEGRAL CONTROL SYSTEM SERVICES, INC.

APPROVED BY: _____ DATE: _____

DRAWING NO. _____ PART NO. _____

THIS SHEET ALSO USED FOR _____

DIMENSIONAL TOLERANCES UNLESS OTHERWISE SPECIFIED:
 MILLIMETRES INCHES
 1 PLACE ± 0.3 mm 2 PLACE ± .01
 2 PLACE ± 0.003 mm 3 PLACE ± .001
 3 PLACE ± 0.015 mm 4 PLACE ± .0005

3rd ANGLE PROJECTION
 DO NOT SCALE DRAWING

QTY. LINE NUMBER(S)		MANUFACTURER/DESCRIPTION		PART (MODEL) #	
PART NO.		SHEET	SHEETS	DRAWING NO.	
				050701-9	
DES. BY	DET. BY	TITLE			
LA	MM	INSTRUMENTATION INTERCONNECTION DIAGRAM			
CHECKED BY	SAFETY OK				
DATE	SCALE	DIVISION:			
	NONE	PLANT:			
		LOCATION/ACTIVITY:			