

4

3

2

1

C

C


B

B

A


A

TRANSMITTER



CABLE ASSEMBLY FURN. WITH ANALYZER

SENSOR




SENSOR BOLTED TO MOUNTING PLATE AFTER PLATE IS WELDED TO WALL BY CUSTOMER

GASKET (By THERMOX)

AMETEK SUPPLIED MOUNTING PLATE WITH 2 7/8" O.D. X 9" LONG NIPPLE (7.30CM X 22.86CM) WELDED TO WALL OVER 3 3/4" O.D. (9.52CM) HOLE BY CUSTOMER.

PROCESS WALL

PROBE



PROPER ORIENTATION FOR MOUNTING PLATE AND FLANGE

SIDE VIEW

ITEM	QTY.	DESCRIPTION
1	4	1/4" O.D. X 1/4" MALE CONN. BRASS PARKER CPI OR EQUAL
2	1	1/4" GATE VA. 150# BRONZE, UNION INSIDE SCREW, RISING STEM, SOLID WEDGE, THR'D ENDS
3	1	1/2" PLUG SOLID CARBON STL. BALV., THR'D
4	*	1/4" O.D. X .035" WALL COPPER TUBING
5	1	1/4" X 4" LG. PIPE NIPPLE SCH. 40 CARBON STL. GALVANIZED
6	1	1/2" X 1/2" X 1/4" RED. TEE 150# M.I. GALV.

CUSTOMER:
PLANT:
CONTRACTING FIRM:

INTEGRAL CONTROL SYSTEM SERVICES, INC.



3586 State Road #4
Cuyahoga Falls, Ohio 44223

Office: 330-923-8900 Fax: 330-923-2116

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. NEITHER THE DRAWING, NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS. NO USE IS TO BE MADE OF IT WHICH IS OR MAY BE INJURIOUS TO INTEGRAL CONTROL SYSTEM SERVICES, INC.

THERMOX O2 ANALYZER

ICSS JOB NO.:
CUST. ORDER NO.:

DATE:	SCALE: NONE
REV	DWN LA
ENGR	
APVD	MM

B 082700-1

AutoCAD File: THERMOXANALYZER.DWG

REV	DATE	CHANGE	ENGR	APVD	REV	DATE	CHANGE	ENGR	APVD

4

3

2

1