



TAG No.	DESCRIPTION	MANUFACTURER	MODEL No.	CALIBRATION	SPEC. No.	INSTALL DETAIL	PURCHASE ORDER	P&ID DWG.
ES-001	POWER SUPPLY, 24VDC	ACCIPTAN						
EV-001	SOLENOID VALVE	ASCO						
HS-001A	SELECTOR SWITCH	ALLEN-BRADLEY		A=AUTO, B=MANUAL				
HS-001B	SELECTOR SWITCH	ALLEN-BRADLEY		A=LOCAL, B=DCS				
HV-001A	ISOLATION VALVE							
HV-001B	ISOLATION VALVE							
LCV-001	CONTROL VALVE	FISHER						
LE-001	LEVEL SENSOR, ULTRASONIC	MILLTRONICS						
LIC-001	CONTROLLER	FOXBORO						
LIK-001	CRT CONSOLE DISPLAY	BAILEY	NOIU02					
LY-001	CHART RECORDER	YOKOGAWA						
LY-001A	TRANSMITTER	MILLTRONICS						
LY-001B	TRANSDUCER, I/P	BRANDT						
LY-001C	CURRENT LOOP ISOLATOR	YOKOGAWA						
LY-001C	I/O CARD (DCS)	BAILEY	NCIS02					
PCV-001	PRESSURE-REDUCING REGULATOR	BELLDIFRAM						

LEGEND:

24 VDC COMMON
 250 OHM RESISTOR

INTEGRAL CONTROL SYSTEM SERVICES, INC.
 1303 BACKETT AVENUE
 Cuyahoga Falls, Ohio 44223
 Office: 330-623-8900 Fax: 330-623-2116

TITLE: TANK NO. 2 LEVEL CONTROL LOOP DIAGRAM
INSTRUMENT TRAINING SIMULATOR

DATE	CHANGE	DWG. No.	021798-1
REV		DATE	
		APPROV. BY:	MM
		DRAWN BY:	LA
		CUSTOMER:	
		DATE:	
		JOB:	

THIS DRAWING IS THE PROPERTY OF INTEGRAL CONTROL SYSTEM SERVICES, INC. UNLESS THE PROPERTY AND INSTRUCTIONS ARE INDICATED OTHERWISE. IT IS TO BE USED ONLY IN CONNECTION WITH THE INSTRUMENT TRAINING SIMULATOR. NO USE IN THE FIELD OR IN ANY OTHER MANNER IS PERMITTED WITHOUT THE WRITTEN CONSENT OF INTEGRAL CONTROL SYSTEM SERVICES, INC.